copyright © HALL Infrastructure DESIGN Ltd.

NOTES:

ALL LEVELS PROPOSED FOR ADOPTION UNDER A SECTION 104 AGREEMENT OF THE WATER INDUSTRY ACT 1991 TO BE CONSTRUCTED IN ACCORDANCE WITH THE WATER UK SEWERS FOR ADOPTION 7th EDITION (WSA) AND SUTTON COUNCIL'S SUPPLEMENT TO WSA (SCC) AND DESIGN AND CONSTRUCTION GUIDANCE (DCG) (1 APRIL 2022).

PRIVATE FOUL DRAIN CONNECTIONS TO BE 150mm dia. uPVC PLASTICS TRAP, 6 m² WHERE SERVING A PLOT) OR (45 kPH) 450mm dia. CARE PLASTICS TRAP, 6 m² WHERE SERVING A PLOT) OR (45 kPH) SPHERICAL VALVES.

ALL SEWERS ARE CIRCULAR, UNLESS WITHIN DOMESTIC CURTILAGE OF DWELLINGS 450mm dia. OR 600mm TYPE SEWERS CLAY PIPES LYSTRA OR EQUIVALENT MAY BE USED WITH THE APPROVAL OF THE ENGINEER.

ALL PIPES TO BE BEDDED & HAUNCHED TO UNDERSIDE OF SURFACE WITH ADAPTED BEDDING OF TYPE B (CLASS 5 TYPE) EXTRA STRENGTH.

ALL PIPEWORK TO BE LAID SUBJECT TO SURVEY UNDER A SYNCHRONISED STATUS