

Note:

- Dimensions are in millimeters.

- Dimensions of the boilers and container might vary ±5%

- These are the minimum clearance distances required. Leaving additional space would provide yourself and service engineers increased access to work around the boiler.

- Concrete pad and hardcore thickness is indicative and require to be specified to suit site ground condition and site activity.



Glendum Close, Pinchbeck, Spalding, Lincs. PE11 3DQ

## Plumbing, Heating, Irrigation, Water & Pumping Services

Tel: 01775 722327 Fax: 01775 725444 email: info@glenfarrow.co.uk

CLIENT:

PROJECT:

GF210 Biomass Boiler Base Dimensions and Elevations & Flue Dimension.

SCALES:	DRAWN:		DATE:	
1:50	AL		08/01/2021	
DRAWING NO: Bio - GF210 016		REV: A		A3