



- ## NOTES
1. DO NOT SCALE.
  2. UNLESS OTHERWISE STATED ALL DIMENSIONS ARE IN MILLIMETRES AND ALL INVERTS IN METRES AOD.
  3. ALL CIVIL WORKS IS THE RESPONSIBILITY OF THE DEVELOPER OR CONTRACTOR INCLUDING FIXING OF STEELWORK SUCH AS ACCESS COVERS AND PENSTOCKS ETC. INSTALLATION OF CABLE DUCTS, BENCHING AND MAKING GOOD AROUND PIPES AFTER INSTALLATION.
  4. REINFORCING BARS ARE TO BE A MINIMUM OF 75MM BELOW THE SURFACE. ANY STRUCTURAL DETAILING / CIVIL WORKS SHOWN SHOWN ON THIS DRAWING ARE ILLUSTRATIVE ONLY UNLESS OTHERWISE STATED AND SHOULD NOT BE USED FOR CONSTRUCTION.
  5. BENCHING IS TO BE FORMED AFTER PUMP INSTALLATION AND TO BE IN ACCORDANCE WITH THE APPLICABLE SEWERS FOR ADOPTION AND ADOPTING AUTHORITY SPECIFICATION.
  6. UNLESS OTHERWISE STATED, ALL DUCTS ARE TO BE Ø100MM AND BE COMPLETE WITH DRAW ROPES. SERVICE DUCTS TO BE TO THE UTILITY SUPPLIERS SPECIFICATION.
  7. DUCT ROUTES ARE SHOWN DIAGRAMMATICALLY ONLY. ALL DUCTS LAID IN THE MOST DIRECT ROUTE TO SUIT THE SERVICE BEING CARRIED AVOIDING ANY ACUTE CHANGES OF DIRECTION.
  8. LEVEL CONTROL POINTS ARE SHOWN DIAGRAMMATICALLY ONLY. THEY WILL BE POSITIONED AWAY FROM OBSTRUCTIONS AND BE READILY ADJUSTABLE AFTER INSTALLATION.

ASSOCIATED DRAWINGS				
No.		TITLE		
NOTES				
REV	DATE	BY	DETAILS	CHK'D
AMENDMENTS				
CLIENT				
<div>ALLISON Homes</div>				
PROJECT				
Middlegate Road, Kirkton				
TITLE				
Pumping Station Details Sheet 3				
DRAWING No: MA10953-605-7			DRAWING STATUS PRELIMINARY	
SCALE 1:20 @A2		DRAWN CMN		ENGINEER CMN
DATE 17/01/20		CHECKED JMCK		APPROVED BY JMCK
<div></div> <p>t: 0115 941 4560 no.1 main hill, nottingham ng1 1jq e: info@millward.co.uk w: www.millward.co.uk</p>				